

**Fire and Emergency Service Department
Nagar Parishad Dhamangaon Railway**

Provisional Noc

NPDmn/FireD/Outward No. 234/2021

Date:-17/08/2021

To,
Vidyaniketan CBSE School,
Dhamangaon Rly.

Sub :- No Objection Certificate

Ref :- Your Letter dated 04/08/2021


Your are being issued a Fire No Objection Certificate for a limited period of time subject to fulfillment of the following conditions under the Maharashtra Fire Prevention and Life Protection Act 2006


1. The NBC 2005 rule has been complied. ✓
2. No Objection Certificate will be mandatory issued only after complete arrangements have been made regarding Fire Safety. ✓
3. Inspection of fire safety system will be mandatory for the licensed agency registered by the Honorable Director Fire Service, Mumbai to do it twice a year, in January and July. ✓
4. The School has fire extinguisher, escape gear blankets, water tank 4000 liter etc. as required. ✓
5. The entire arrangements have been made as per safety audit. ✓
6. Emergency fire exists and fire signage's are arranged. ✓
7. Fire safety audit report should be submitted within 1 month now as per Appendix-1, Appendix-2,
8. The No Objection Certificate will only be valid for the next six months from today. But it is mandatory to conduct fire safety audit twice a year.
9. Fire Safety Audi's Fire Certificate must be submitted to the office within seven days now. And you will be fully responsible for it. Fire Certificate is submitted.
10. If any further incident occurs due to lack of management as mentioned above, the entire responsibility will remain with the management. You are being issued a Fire No Objection Certificate subject to fulfilling the above mentioned terms and condition will result in termination of your No Objection Certificate and you will be solely responsible for it.

(Validity of No Objection Certificate From 13/08/2021 to 12/02/2022)

Note:- As per the Government rules, it is mandatory to submit the form B every six months.


Director
Vidyaniketan CBSE School,
Dhamangaon Rly.


Principal
Vidyaniketan CBSE School,
Dhamangaon Rly.


Fire Supervisor
Nagar Parishad, Dhamangaon Rly.

(Transleted Copy)